Satin Finish Console Outlet Quick Disconnect

Puritan-Bennett Compatible





Features:

- Flow rate exceeds the requirements of NFPA
- Accepts only Puritan-Bennett gas-specific adapters
- 100% pressure testing of each outlet and cleaned for medical gas service
- Indexed to eliminate interchangeability of gas services
- Up to 3/4" [19 mm] mounting plate thickness adjustment
- 360° swivel inlet pipe for easy installation
- Universal rough-in assembly to accept Quick Disconnects or DISS Front Adapters (Can be interchanged at any time)
- Outlets are also available for M.R.I. use

General Specifications:

The medical gas outlet shall be an Amico Alert-1 series.

Outlets shall be manufactured with a 7-3/4" [197 mm] length type "K" 1/2" [12.7 mm] outside diameter (3/8" nominal) size copper inlet pipe stub which is silver brazed to the outlet body. The body shall be of 1-5/16" [33 mm] diameter, one piece brass construction. For positive pressure gas services, the outlet shall be equipped with a primary and secondary check valve and the secondary check valve shall be rated at a maximum of 200 psi [1,379 kPa] in the event the primary check valve is removed for maintenance. Outlet bodies shall be gas-specific by indexing each gas service to a gas-specific single pin indexing arrangement on the respective identification module.

A satin finish, color coded front plate shall be used for gas identification and aesthetic appeal.

With the back rough-in mounted the outlet shall adjust up to 3/4" [19 mm] variation in mounting plate thickness.

The latch valve assembly shall be Puritan-Bennett Quick Disconnect compatible and accept only corresponding Puritan-Bennett type gas-specific adapters.

All M.R.I. outlets are manufactured from nonferrous materials.

All outlets shall be cleaned and degreased for medical gas service, factory assembled and tested.

The outlets are UL Listed and ETL Listed.

Amico products comply with NFPA 99.


Project





Technical Specifications





Model Numbers

Complete Puritan-Bennett Compatible satin finish console outlet assembly The "		The "L" Defines the Lan	he "L" Defines the Language:	
O-PBCON-L-XXX-S		U = English (NFP	A) OXY,	
		AIR, VAC and WAG		
		$E = N_2O \text{ and } CO_2$	2	
NOTE: The complete Puritan-Benr				
outlet assembly will consist of:		The "XXX" Defines the Gas:		
QTY. 1	O-FPOC-PB-L-XXX	Oxygen	= OXY	
	(Front Latch Assembly)	Medical Air	= AIR	
		Carbon Dioxide	= CO2	
QTY. 1		Nitrous Oxide	= N2O	
	O-BAKCON-L-XXX-S	MedVac ¹	= VAC	
	(Rough-in Assembly)	Waste Anesthetic		
		Gas Disposal (NFPA)	= WAG	
QTY. 1	O-TRIM-P275G			
	(Trim Plate)	¹ Please see note above		

M.R.I. Model Numbers



Complete Puritan-Bennett compatible satin finish console outlet assembly

Γ	The "L" Defines the Lan U = English (NFP	
	U = Enalish (NFP)A) OVV
O-PBCONM-L-XXX-S		$A) \cup A i,$
	AIR, VAC and V	VAG
	$= N_2O$ and CO_2	2
nnett compatible satin finish console	The "XXX" Defines the Gas:	
	Oxygen	= OXY
	Medical Air	= AIR
O-FPOM-PB-L-XXX (Front Latch Assembly)	Carbon Dioxide	= CO2
	Nitrous Oxide	= N2O
	MedVac ¹	=VAC
	Waste Anesthetic	
O-BAKCONM-L-XXX-S (Rough-in Assembly)	Gas Disposal (NFPA)	= WAG
	¹ Please see note above	
	ennett compatible satin finish console O-FPOM-PB-L-XXX (Front Latch Assembly) O-BAKCONM-L-XXX-S	ennett compatible satin finish console O-FPOM-PB-L-XXX (Front Latch Assembly) D-BAKCONM-L-XXX-S (Rough-in Assembly) E = N ₂ O and CO The "XXX" Defines the Oxygen Medical Air Carbon Dioxide Nitrous Oxide MedVac¹ Waste Anesthetic Gas Disposal (NFPA)

QTY. 1 **O-TRIM-P275G**

(Trim Plate)

Distributed	by: